

**SPANISH FORK CITY**  
**500 E and 700 E Water Main Replacement Project**  
**March 22, 2004**

***ADDENDUM #1***

**1. Bid Schedule.** Bids must be submitted on the updated bid schedule included with this addendum.

**2. Connect Water Service to Proposed Main (Item 11).** This item shall include all labor, equipment and material required to connect proposed and existing water service lines to the proposed water main according to City standards. The cost of connection shall not be included in any other item.

**2.01. Payment.** Payment shall be made for each service connection made to the proposed water main.

**3. Mechanical Restraints.** As indicated in the special conditions all fittings shall have mechanical type restraints installed to City standards. This includes fittings for water mains and fire hydrant lines.

# SPANISH FORK CITY

500 East and 700 East Water Replacement Project  
 Bid Schedule - Addendum #1

Note: Bids shall include sales tax and all other applicable taxes and fees.

NO.	ITEM	UNIT	QTY	UNIT PRICE	TOTAL PRICE
1	4" C900 PVC Water Main	LN FT	5		
2	6" C900 PVC Water Main	LN FT	99		
3	8" C900 PVC Water Main	LN FT	2,694		
4	8" Gate Valve	EACH	8		
5	Abandon Existing Valve Box	EACH	3		
6	Fire Hydrant	EACH	4		
7	Remove Fire Hydrant	EACH	1		
8	1" Water Meter	EACH	23		
9	1" Water Meter with Traffic Rated Box	EACH	6		
10	1" Water Service Line	LN FT	1,131		
11	Connect Water Service to Proposed Main	EACH	47		
				<b>TOTAL :</b>	

\_\_\_\_\_  
 TOTAL WRITTEN OUT

RESPECTFULLY SUBMITTED:

\_\_\_\_\_  
 SIGNATURE / TITLE

\_\_\_\_\_  
 COMPANY

\_\_\_\_\_  
 LICENSE #

\_\_\_\_\_  
 DATE

(SEAL - IF BY A CORPORATION)

\_\_\_\_\_  
 STREET ADDRESS

ATTEST \_\_\_\_\_

\_\_\_\_\_  
 CITY / STATE / ZIP CODE