

## SPANISH FORK CITY

### 2005 Water Replacement Project 800 North, Expressway & 800 East

#### ***ADDENDUM #1*** ***February 10, 2005***

**1. Casing Specifications.** As indicated in the plans and specifications there is an existing casing across highway 6. This is an empty 24 inch steel casing installed in anticipation of this project. The specifications for installing the PVC pipe in the casing are included with this addendum.