



NOTES:

1. FIRE HYDRANTS SHALL BE PAINTED RED.
2. ALL BOLTS SHALL BE FREE FROM CONCRETE AND FULLY ACCESSIBLE.
3. IF THERE IS NOT A PLANTER STRIP, THE CENTER OF THE HYDRANT SHALL BE LOCATED 24" BEHIND THE SIDEWALK WITH A 4' BY 4' CONCRETE PAD CENTERED ON THE HYDRANT.
4. THERE SHALL BE NO OBSTACLES INCLUDING BUT NOT LIMITED TO POLES, UTILITY BOXES, TREES, FENCES, OR WALLS WITHIN 3' OF HYDRANT.
5. RISERS MAY ONLY BE USED WHEN AUTHORIZED BY THE CITY ENGINEER OR HIS/HER DESIGNEE.



SPANISH FORK CITY
 40 SOUTH MAIN STREET
 SPANISH FORK, UT 84660
 (801) 804-4550

STANDARD DRAWING

FIRE HYDRANT

DRAWN: JLR
 DESIGN: CJP
 CHECK: CMT
 DATE: 6/22/16

SCALE: NONE
 STANDARD 13