



- NOTES:**
1. STANDARD SERVICE SIZE SHALL BE 1" CONTINUOUS SDR-9 CTS 200 PSI PURPLE POLYPROPYLENE PIPE.
  2. STAINLESS STEEL LINER INSERTS WILL BE REQUIRED INSIDE OF TUBING AT COMPRESSION FITTINGS.
  3. ALL FITTINGS SHALL BE COMPATIBLE WITH SERVICE SIZE.
  4. SERVICE LATERAL SHALL SLOPE TOWARDS PRESSURIZED IRRIGATION MAIN.
  5. SPRINKLER SLEEVE SHALL NOT BE IN LINE WITH ANY UTILITY BOXES.
  6. 1-1/2" POLY CONDUIT SHALL BE BURIED 12" BELOW GRADE.
  7. FOR TRAFFIC AREAS, USE A CDR SYSTEMS CORP 16X21X18 FIBERGLASS REINFORCED POLYMER CONCRETE BOX WITH "IRRIGATION" MARKED ON THE LID.



**SPANISH FORK CITY**  
 40 SOUTH MAIN STREET  
 SPANISH FORK, UT 84660  
 (801) 804-4550

**STANDARD DRAWING**

1" PRESSURIZED IRRIGATION SERVICE BOX AND LATERAL

DRAWN:	JLR
DESIGN:	CJP
CHECK:	CMT
DATE:	6/22/16

SCALE:	NONE
STANDARD	19