



NOTES:

1. THE TOP OF ALL R-TANK CHAMBERS ALONG A CONTINUOUS SECTION OF CHAMBERS SHALL BE DESIGNED TO BE A MINIMUM OF 3" BELOW THE GUTTER FLOWLINE AT THE INLET.
2. ALL PLANTER AREAS BETWEEN THE CURB AND SIDEWALK SHALL BE LANDSCAPED WITH PERVIOUS MATERIALS UNLESS OTHERWISE APPROVED BY THE CITY ENGINEER OR DESIGNEE.



SPANISH FORK CITY
40 SOUTH MAIN STREET
SPANISH FORK, UT 84660
(801) 804-4550

STANDARD DRAWING

LOW IMPACT DEVELOPMENT (LID) FOR RESIDENTIAL STREETS

DRAWN: JLR
DESIGN: CJP
CHECK: CMT
DATE: 6/22/16

SCALE:
NONE
STANDARD
30