



NOTES:

1. SECTIONALIZER CABINET UNITS FOR 200 AMP 1 PHASE ARE TO BE FABRICATED FROM FIBERGLASS COMPOSITE & MEET SPANISH FORK ELECTRIC'S SPECIFICATIONS. CONDUIT OPENINGS MUST BE WITHIN THE GROUND SLEEVE WINDOW OF THE SECTIONALIZER.
2. BLOW IN 1350 LB. MULE TAPE IN ALL CONDUITS AND TIE SECURELY TO 4 POINT MOUNTING PLATE.
3. 200 AMP 1 PHASE SECTIONALIZER P/N: NORDIC ND-150-MG-101-X-X OR AN APPROVED EQUIVALENT.
4. CONTRACTOR TO FURNISH & INSTALL 200-AMP 4-POINT MOUNTING JUNCTION PLATES & 4 POINT JUNCTIONS.
5. RIGID METAL (RMC) OR FIBERGLASS (F.G.) SHALL BE USED FOR ALL ELBOWS, OR BENDS 45 DEGREES OR GREATER.
6. SFCN COMMUNICATIONS ELBOWS SHALL BE LONG SWEEP (36") RMC OR F.G..
7. SECTIONALIZER SHALL BE SET A MINIMUM OF 6" BEHIND SIDEWALK
8. CONCRETE SHALL BE POURED IN FRONT OF THE SECTIONALIZER IN BETWEEN THE SECTIONALIZER & SIDEWALK.
9. AREA AROUND SECTIONALIZER SHALL BE BACKFILLED AND LEVELED A MINIMUM OF 12' IN ALL DIRECTIONS AROUND THE SECTIONALIZER TO PROVIDE A SAFE WORKING AREA FOR THE ELECTRIC DEPARTMENT.



SPANISH FORK CITY
 40 SOUTH MAIN STREET
 SPANISH FORK, UT 84660
 (801) 804-4550

STANDARD DRAWING

200-AMP 1 PHASE SECTIONALIZER

DRAWN: JLR
 DESIGN: CJP
 CHECK: CMT
 DATE: 6/22/16

SCALE:
 NONE
 STANDARD
 69