



CONCRETE PAD DETAIL

NOTES:

1. SECTIONALIZER CABINET UNITS FOR 600 AMP 3 PHASE ARE TO BE FABRICATED FROM FIBERGLASS COMPOSITE & MEET SPANISH FORK ELECTRIC'S SPECIFICATIONS. CONDUIT OPENINGS MUST BE WITHIN THE GROUND SLEEVE WINDOW OF THE SECTIONALIZER.
2. BLOW IN 1/4" POLY ROPE AND TIE SECURELY TO 4 POINT MOUNTING PLATE.
3. GROUND SLEEVE AND CAP SHALL HAVE #4 REBAR 12" ON CENTER IN ALL DIRECTIONS. USE PRE-CAST CEMENT GROUND SLEEVE AND CAP WITH DIMENTIONS AS SHOWN ABOVE.
4. CONTRACTOR TO FURNISH & INSTALL 600-AMP 4-POINT MOUNTING JUNCTION AND PLATES & 4-POINT JUNCTION



SPANISH FORK CITY
 40 SOUTH MAIN STREET
 SPANISH FORK, UT 84660
 (801) 804-4550

STANDARD DRAWING

600-AMP 3 PHASE FIBERGLASS SECTIONALIZER

DRAWN:	JLR
DESIGN:	CJP
CHECK:	CMT
DATE:	6/22/16

SCALE:	NONE
STANDARD	71