



NOTES:

1. SWITCH GEAR GROUND SLEEVE SHALL BE PROVIDED BY SPANISH FORK ELECTRIC AND INSTALLED BY ELECTRICAL CONTRACTOR AS PER CITY SUPPLIED LAYOUT
2. 1/4" POLY ROPE SHALL BE BLOWN INTO CONDUIT AND TIED SECURELY TO GROUND ROD
3. CONDUIT LAYOUT DETAIL SHALL BE GIVEN BY SPANISH FORK ELECTRIC DURING PRE CONSTRUCTION MEETING
4. TYPICAL FOR COMMERCIAL TRANSFORMER PROTECTION FOR 750KVA AND LARGER



SPANISH FORK CITY
 40 SOUTH MAIN STREET
 SPANISH FORK, UT 84660
 (801) 804-4550

STANDARD DRAWING

600 AMP PSE 3/5 SWITCHGEAR

DRAWN:	TC
DESIGN:	TC
CHECK:	KP
DATE:	6/22/16

SCALE:	NONE
STANDARD	73